



SIRIM QAS INTERNATIONAL SDN. BHD.

(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri, Seksyen 2, Peti Surat 7035, 40700 Shah Alam, Selangor Darul Ehsan, Malaysia
Tel : 603-5544 6400 Emel : cserviceqas@sirim.my www.sirim-qas.com.my

File No : P5-006050
Licence No : FL000002

Date : 05/12/2022

K-FLEX MALAYSIA SDN BHD
LOT 2752, JALAN RAJA NONG
TAMAN KLANG JAYA
41200 KLANG
SELANGOR, MALAYSIA

Attn : ZULKIFLI BIN YUSOF

Tel No : 03-51627899

Fax No : 03-51623799

Dear Sir/Madam,

Fire Listing Licence

Product : ELASTOMERIC THERMAL INSULATION

Standard : BS 476 : PART 6 : 1989 + A1 : 2009 BS 476 : PART 7 : 1997

With regards to your request for new/renewal/changes of licence(s) under the SIRIM Fire Listing Licence scheme, enclosed please find the copy of the licence(s) and the certification report(s) for your safe keeping.

For enquiry, please contact

Officer Name : MOHAMMAD IRFAN BIN NORHASNI

Contact No : 603-55446456

Email : irfanhasni@sirim.my

Thank you.

This is a computer generated document. No signature is required.

SIJIL BARANGAN TERSENARAI

Product Listing Certificate



**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to**

**K-FLEX MALAYSIA SDN BHD
LOT 2752, JALAN RAJA NONG
TAMAN KLANG JAYA
41200 KLANG
SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai
a certificate to use the Listed Product Mark on**

ELASTOMERIC THERMAL INSULATION

Please refer to detail in the SCHEDULE

**sebagai mematuhi keperluan
as complying with**

**BS 476 : PART 6 : 1989 + A1 : 2009
BS 476 : PART 7 : 1997**



Nur Fadhilah binti Muhammad
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

K-FLEX MALAYSIA SDN BHD



Trade Mark : K-FLEX
Model : EC
Rating : Nominal Density: 50 kg/m³ (Thickness: 10 mm, 19 mm), 58 kg/m³ (Thickness: 32 mm)
Fire Propagation Index, I: 1.7, 1.9, 3.6
Surface Spread of Flame: Class One
Type : Tube & Sheet
Size : Nominal thickness:: 10mm, 19mm & 32mm

TEST REPORT NO. : 2016FE0470, 2016FE0471, 2016FE0472, 2016FE0473,
2016FE0474, 2016FE0475

End of page
