



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 080975 0012 Rev. 01

Initial No. CLS2 080975 0012 Rev. 00

Certificate Holder: K-Flex Malaysia Sdn Bhd
Lot 2752 Jalan Raja Nong
Taman Klang Jaya
41200 Klang
MALAYSIA

UEN - 748619-H

Product: Thermal Insulation Materials

Brand Name: K-Flex

Model(s): K-Protect

Product Details: Rating: Class 0
Thickness: 7.4mm ~ 50mm
Bulk Density: 39kg/m³
Tested on the Reinforced Aluminium Foil face

Regulated Fire Safety Products used in Singapore need to comply with Singapore Civil Defence Force's Requirements

This certificate is for use outside of Singapore only

Standard(s): BS 476-6:1989/A1:2009
BS 476-7:1997

Country of Origin: Malaysia

Test Report(s): 7191215525-MEC19/4-YWA_CR2,
7191215525-MEC19/5-YWA_CR2,
7191247839-MEC20/1-YWA_CR1,
7191247839-MEC20/2-YWA_CR1,
TÜV SÜD PSB Assess 7191247839-MEC20/03-DA_CR1

Valid until: 2025-03-09

Page 1 of 1

Issued on: 2021-04-16

Vice-President (Certification Department)
TÜV SÜD PSB



PD-2002-01

This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuv-sud-psb.sg