



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 080975 0016 Rev. 01

Initial No. CLS2 13 03 80975 001

Certificate Holder:	K-FLEX MALAYSIA SDN. BHD. Lot 2752, Jalan Raja Nong Off Jalan SG. Jati Taman Klang Jaya 41200 Klang Selangor MALAYSIA UEN - 200601028863 (748619-H)
Local Representative:	K-Flex (Singapore) Pte Ltd 10 Anson Road, #22-02 International Plaza, Singapore 079903, SINGAPORE UEN - 202004078K
Product:	Thermal Insulation Materials
Brand Name:	K-Flex ST
Model(s):	K-Flex ST
Product Details:	Rating: Class 0 Thickness: 6mm ~ 50mm Bulk Density: 46kg/m ³ ~ 86kg/m ³ Tested on the Elastomeric Foam Insulation face adhered to an approximately 1mm thick Galvanised Steel sheet
Standard(s):	BS 476-6:1989/A1:2009 BS 476-7:1997
Country of Origin:	Malaysia, People's Republic of China
Test Report(s):	Refer to following page(s)
Valid until:	2028-04-11

Page 1 of 2

Issued on: 2024-09-20

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 080975 0016 Rev. 01

Initial No. CLS2 13 03 80975 001

Test Report (s):

7191326564-MEC24/A1-YWA, 7191326564-MEC24/A2-YWA,
7191326564-MEC24/B1-YWA, 7191326564-MEC24/B2-YWA,
7191034208-PIC12/1-OKH, 7191034208-PIC12/2-YWA,
7191261014-MEC21/1-YWA, 7191261014-MEC21/2-YWA,
TÜV SÜD PSB Assess 7191326564-MEC24-JV,
TÜV SÜD PSB Assess 7191261014-MEC21/03-DA,
TÜV SÜD PSB Validity Letter 7191261014-MEC21/03-DA dated 2023-04-11

Replacement History:

Predecessor Certificate (Issue Date)
CLS2 15 03 80975 005 (2015-03-30)
CLS2 18 02 80975 008 (2018-02-12)
CLS2 080975 0008 Rev. 01 (2021-06-04)
CLS2 080975 0008 Rev. 02 (2021-09-09)
CLS2 080975 0016 Rev. 00 (2023-05-08)

Page 2 of 2

Issued on: 2024-09-20

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuvsud.com/sg